



APRAGAZ

a.s.b.l.
Your Inspection Authority



Chaussée de Vilvorde, 156 B-1120 Brussels
Phone 32/2/264 03 60 - Fax. 32/2/268 89 58
e-mail : info@apragaz.com - V.A.T. BE 407.199.070

BETA Corporation s.r.o.
Slavojova 579/9

CZ - 128 00 Praha 2
CZECH REPUBLIC

Y/Ref. :
O/Ref. : CHL/FB/PRODUCT CERTIFICATION/BUILDINGS/BETA/2012-09-21.

Brussels, 21 September 2012.

APPROVAL CERTIFICATE EN3 – PORTABLE FIRE EXTINGUISHERS

We hereby declare that the hereafter mentioned extinguishers were approved according to the requirements of the EN3-7 standards and according to the hereafter mentioned tests reports :

Mark	Type	Nominal charge	Achieved fire ratings	EN3-7 test report nr
BETA	P2 BETA-L	2 kg ABC powder Type "HJ ABC SUPER POWDER"	13 A - 70 B	EN 11121
BETA	CO2 BETA-S	2 kg CO ₂	34 B	EN 11122

The General Manager,

Christian LEPLAT, ir